



Isolateurs / Insulators

| REFERENCES | Numéro de catalogue / Catalog number | 52-5(NJ120Z / 146) | |
|---------------------------------|-----------------------------------------|---------------------------|-----|
| | ANSI C29.2 | 52-5 | |
| Leakage Distance | | mm | 320 |
| Mechanical Failing Load | | kN | 120 |
| Mechanical Impact Strength | | N.m | 17 |
| Low Frequency Withstand Voltage | Wet | kV | 45 |
| Impulse Withstand Voltage | | kV | 100 |
| Low Frequency Flashover Voltage | Dry | kV | 80 |
| | Wet | kV | 50 |
| Low Frequency Puncture Voltage | | kV | 130 |
| Radio Influence Voltage | Low Frequency test Voltage | kV | 10 |
| | Max RIV | µV | 50 |

| ITEM | QTY | DESCRIPTION | MATERIAL |
|------|-----|------------------|---------------------------------|
| 1 | 1 | Cap | Spheroidal cast Iron |
| 2 | 1 | Split Cotter Pin | Stainless Steel |
| 3 | 1 | Cement | Aluminous Cement |
| 4 | 1 | Glass Shell | Toughened Glass TM Saint Gobain |
| 5 | 1 | Pin | Forged Steel |

ISOLATEUR D'ALIGNEMENT EN VERRE SUSPENSION GLASS INSULATOR