



BLOC DE TRIFURCATION / TERMINAL BLOC

PTS CAT. #: **T6001964**

BLOC DE TRIFURCATION / TERMINAL BLOCK 35kA



MALT / GROUNDING

CAPACITÉ ÉLECTRIQUE / ELECTRICAL RATING

Capacité / Current Rating	[kA]	35
Courant Continu / Continuous Rating	[Amps]	400
Court-Circuit / Fault Current	15 Cycles	43 000
Court-Circuit / Fault Current	30 Cycles	30 000

CAPACITÉ MÉCANIQUE / MECHANICAL RATING

Couple de Serrage / Recommended Torque	[Pouce/Lbs]/[Inch/Lbs]	221
Câble de MALT Maximal / Maximum Jumper Range		4/0
Câble de MALT Minimum / Minimum Jumper Range		# 2
Poids / Weight		0.8 Lbs / 0.3Kg.
Désignation ASTM / Designation ASTM	F 855	