



**BLOC DE TRIFURCATION / TERMINAL BLOC**

PTS CAT. #: **T6001964**

**BLOC DE TRIFURCATION / TERMINAL BLOCK 35kA**



**MALT / GROUNDING**

**CAPACITÉ ÉLECTRIQUE / ELECTRICAL RATING**

Capacité / Current Rating	<b>[kA]</b>	43
Courant Continu / Continuous Rating	<b>[Amps]</b>	400
Court-Circuit / Fault Current	<b>15 Cycles</b>	43 000
Court-Circuit / Fault Current	<b>30 Cycles</b>	30 000

**CAPACITÉ MÉCANIQUE / MECHANICAL RATING**

Couple de Serrage / Recommended Torque	<b>[Pouce/Lbs]/[Inch/Lbs]</b>	221
Câble de MALT Maximal / Maximum Jumper Range		4/0
Câble de MALT Minimum / Minimum Jumper Range		# 2
Poids / Weight		0.8 Lbs / 0.3Kg.
Désignation ASTM / Designation ASTM	<b>F 855</b>	